

Active Council Issues								
No.	Initiated	Research	Approval	Title	Description	Status / Actions	Opened	Targeted Close Date
UC67	OMO	UC	EC	Vacant UC position	The alternate Federal-Non DOD DOI position is vacant.	<b>23Apr18:</b> The OMO was informed that Mr. Kenneth Hallett is no longer working for the BLM.	<b>23-Apr-18</b>	<b>30-Dec-18</b>
UC74	OMO	UC	EC	Vacant UC position	The primary DOD JBER position is vacant.	<b>6Jun19:</b> The OMO was informed that MSgt Connolly was no longer the primary representative and had moved to another position. MSgt Corey Spittler is to take his place but no appointment letter has been received to date. <b>13Aug19:</b> Appointment letter received naming MSgt Cory Spittler as the new primary.	6-Jun-19	30-Aug-19
UC75	OMO	UC	EC	Vacant UC position	The alternate DOD JBER position is vacant.	<b>6Jun19:</b> The OMO was informed that SSgt Paice was no longer the alternate representative. TSgt Schwing is to take his place but no appointment letter has been received to date. <b>13Aug19:</b> Appointment letter received naming TSgt Brandon Schwing as the new alternate.	6-Jun-19	30-Aug-19
UC76	OMO	UC	EC	Vacant UC position	The alternate SOA DPS position is vacant.	<b>31Jul19:</b> Mr. Leon Morgan was appointed as the new Deputy Commission for Public Safety leaving the alternate position vacant.	31-Jul-19	30-Sep-19
UC77								
Active Operational Issues								
No.	Initiated	Research	Approval	Title	Description	Status / Actions	Opened	Targeted Close Date
OP02	OMO	USARAK	UC	Birch Hill Master Site	Four of eight rectifiers have failed.	<b>7Feb18:</b> Per discussion at Feb 7 UC meeting, Mr. Rick Williams took action item to follow up on status of paperwork submittal for the funding to correct this discrepancy. <b>7Mar18:</b> Mr. Williams advised the funding request had been submitted but there is no forward motion on getting this resolved. <b>19Jul18:</b> USARAK expects funds to be available in DOD FY19. <b>27Mar19:</b> Down to 3 out of 8 rectifiers. Loss of one more could take all of Zone 2 offline (site trunking only). <b>3Apr19:</b> Mr. Williams briefed that the Department of Public Works is doing the work at Birch Hill and the parts are on order and funds requested. <b>10Jun19:</b> Mr. Williams informed the OMO that DPW had now rejected the project and he was looking at a local contractor to do the work. <b>7Aug19:</b> Mr. Williams informed the UC there are two contracts in the works for the project; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.	7-Feb-18	31-Dec-19
OP05	OMO	OIT	UC	MW Refresh	Outages caused by MW bouncing (Glenn Hwy to Richardson Hwy)	<b>7Feb18:</b> Funds were identified to replace this string of legacy MW last last year. Request to purchase was denied. <b>6Feb19:</b> Funding for replacement is now in the procurement process.	7-Feb-18	30-Dec-20
OP06	OMO	JBER	UC	R1 North	Rectifier issue	<b>11Mar19:</b> One of the six rectifiers at the R1 North site has failed. <b>26Mar19:</b> Per SSgt Paice, they are working to get quotes to get the battery banks and the rectifiers replaced.	11-Mar-19	30-Sep-19
OP07	OMO	SOA	UC	Quantars	Replacement of SOA Quantars	<b>12Mar19:</b> The ALMR System cannot go beyond the 7.17 software platform until the SOA completes the replacement of all of its Quantars.	12-Mar-19	31-Dec-20
OP08	OMO	USARAK	UC	Black Rapids	Battery plant failed testing	<b>3Apr19:</b> The SOA tested the battery plant at Black Rapids and found some of the battery cells are dead. Battery plant needs replaced. <b>7Aug19:</b> Mr. Williams stated Black Rapids was still being looked at; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.	3-Apr-19	31-Dec-19
OP09	OMO	USARAK	UC	Fort Greely	Site has no battery backup	<b>3Apr19:</b> The Fort Greely has only commercial power. If power fails, there is no battery backup and the site will go down until power is restored. <b>7Aug19:</b> Mr. Williams stated Fort Greely has some dead batteries and the same old rectifiers, and the DC system needs to be replaced.; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.	3-Apr-19	31-Dec-19
OP10	OMO	USARAK	UC	Donnelly Dome rectifiers	Rectifier issue	<b>3Apr19:</b> The rectifiers at Donnelly Dome need to be replaced. They are the same make as the ones at Birch Hill. No spares available and no one will work on them. <b>7Aug19:</b> Mr. Williams stated Donnelly Dome needs a new DC power system; the site could see a power refresh and they expect to submit the projects through the Defense Logistics Agency and through the Department of Public Works, possibly as soon as next week.	3-Apr-19	31-Dec-19
OP11	OIT	OIT	UC	Delta	Generator	<b>3Apr19:</b> The generator at the Delta site needs replaced.	3-Apr-19	31-Dec-19
OP12	OIT	Clear	UC	Clear	Microwave	<b>3Apr19:</b> The Clear microwave needs to be modernized	3-Apr-19	30-Jun-20
OP13								
Issues CLOSED at, or since, the last meeting								

**NOTE: Yellow highlight indicates change since last meeting**